

The Texas A&M University System

ORGANIZATION		DEPARTMENT	
Organization	AM02 - Texas A&M University	Department	02UTIL
Address	401 Joe Routt Boulevard College Station, TX 77843	Bill-to-Address	750 Agronomy Road - Suite 3101 6000 TAMU Attn: Email invoices to invoices@tamu.edu Attn: Do not mail invoice if sending via email College Station, TX 778436000
Purchaser	Clyde Oberg	Ship-to-Address	CENTRAL UTILITY PLANT RECEIVING 496 ASBURY STREET 1584 TAMU COLLEGE STATION, TX 778431584
Info Contact	CLYDE OBERG 979-845-1042 co@tamu.edu		

BID INFORMATION			
Description	MR#23155 / CENTURY SQUARE CABLE		
Bulletin Desc.			
Bid Number	AM02-17-B000903	Bid Opening Date	02/23/2017 2:00 PM
Bid Type	Open Market	Type Code	Invitation for Bid
Alternate Id	89434AF	Fiscal Year	2017
		Available Date	02/09/2017 5:00 PM
Pre-Bid Conference			
Attachments	BAM Registration info~68.pdf Best Value Criteria~14.doc TAMU Ts AND Cs~28.pdf		

AMENDMENTS

ITEMS					
Item	Description	Quantity	Unit	Unit Price	Total
1.000	750 15 KV cable aluminum as specified: 750 MCM ALUMINUM 15 KV SHIELDED POWER CABLE 15,000 VOLT, 133% INSULATION LEVEL TYPE MV-105, WET OR DRY LOCATION, INDOORS OR OUTDOORS, SUNLIGHT RESISTANT FAST, CLEAN STRIPPING THERMOSETTING INSULATION SHIELD EXTRUDED SEMICONDUCTOR CONDUCTOR SHIELD ETHYLENE PROPYLENE RUBBER WITH NOMINAL THICKNESS OF 0.220" 5 MIL BARE COPPER TAPE SHIELD, HELICALLY APPLIED WITH 25% OVERLAP JACKET MATERIAL SHALL BE THERMOSET CHLORINATED POLYETHYLENE 105 C CONTINUOUS OPERATING TEMPERATURE 140 C EMERGENCY RATING 250 C SHORT CIRCUIT RATING ALUMINUM CONDUCTOR, CLASS B STRANDED APPROVED MANUFACTURERS: GENERAL CABLE PRYSMIUM OKONITE SOUTHWIRE	5,310.00	FT		
2.000	TO BE PROVIDED IN THE FOLLWOING LENGTHS: Three (3) reels @ 1070'/each. Total of 3210' Three (3) reels @ 700'/each. Total of 2100'	0.00			
3.000	NO ALTERNATE SUBMISSION OR ALTERNATE VENDORS WILL BE CONSIDERED. CABLE TO BE EXACTLY AS SPECIFIED BY THE APPROVED VENDORS.	0.00			